

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: A**D**** (Bulletin A9)
Equipment Description: Hoffman NEMA Type 9
Enclosure Rating : CSA Class II, Groups E, F, and G
Enclosure Certification: CSA C22.2 No. 0-M1991

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class II, Groups E, F and G

Enclosures, fabricated steel, Cat Nos. A-8D64, -8D84, -10D84, -10D106, -12D106, -12D126, -12D128,
-16D126, -16D128, -16D166, -20D168, -20D208, -24D208, -24D2410, -30D2410, -36D3012,
-48D3612, threaded for conduit connection or field drilling and tapping, conduit sizes 1/2 in through 2 in

Applicable Standards: CSA C22.2 No. 0-M1991 – General Requirements – Canadian Electrical
Code, Part II
CSA C22.2 No. 0.4-M1982 – Bonding and Grounding of Electrical
Equipment
CSA C22.2 No. 0.5-M1982 – Threaded Conduit Entries
CSA C22.2 No. 25-1966 – Enclosures for Use in Class II, Groups E, F & G
Hazardous Locations

Authorized by:



5/22/2020 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

Subject to Change Without Notice

DOC: CERT-00242-A



Certificate of Compliance

Certificate: 1675743

Master Contract: 151630

Project: 1675743

Date Issued: 2005/06/03

Issued to: Hoffman Enclosures Inc.
2100 Hoffman Way
Anoka, MN 55303-1745
USA
Attention: Tom Hurney

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ezio Migliozi

Authorized by: Nick Alfano, Operations
Manager

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class II, Groups E, F and G

Enclosures, fabricated steel, Cat Nos. A-8D64, -8D84, -10D84, -10D106, -12D106, -12D126, -12D128, -16D126, -16D128, -16D166, -20D168, -20D208, -24D208, -24D2410, -30D2410, -36D2410, -36D3012, -48D3612, threaded for conduit connection or field drilling and tapping, conduit sizes 1/2 in through 2 in.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 0-M1991 - General Requirements -Canadian Electrical Code, Part II

CSA C22.2 No. 0.4-M1982 - Bonding and Grounding of Electrical Equipment



Certificate: 1675743

Master Contract: 151630

Project: 1675743

Date Issued: 2005/06/03

CSA C22.2 No. 0.5-M1982 - Threaded Conduit Entries

CSA C22.2 No. 25-1966 -Enclosures for Use in Class II, Groups E, F and G Hazardous Locations.